



- NOTES:
- 1) STANDARD THERMOSTAT IS N.O., N.C. IS OPTIONAL. QUANTITY WILL VARY DEPENDING UPON SIZE
 - 2) SHOWN WIRED FOR 480V.
 - 3) O INDICATES PLUG IN CONNECTIONS.
 - 4) DOTTED LINES INDICATE USER SUPPLIED WIRING.
 - 5) UNIT MUST BE GROUNDED.
 - 6) 30-60A MODELS FANS NOT REQUIRED AND QUANTITY WILL VARY DEPENDING UPON SIZE.
 - 7) 30A CT REQUIRES 2 PRIMARY TURNS.

REVISIONS				REVISIONS				REVISIONS				REVISIONS				REVISIONS														
CHANGE NO.	ECO NO.	DESCRIPTION	DATE	BY	APP	CHANGE NO.	ECO NO.	DESCRIPTION	DATE	BY	APP	CHANGE NO.	ECO NO.	DESCRIPTION	DATE	BY	APP	CHANGE NO.	ECO NO.	DESCRIPTION	DATE	BY	APP	CHANGE NO.	ECO NO.	DESCRIPTION	DATE	BY	APP	
												1	14-H016	REV TITLE BLOCK, NOTES, CT'S	08/18/14	JDA	SCW													

THIS DRAWING AND ALL INFORMATION CONTAINED HEREIN IS THE PROPERTY OF AMETEK HDR POWER SYSTEMS. MAY NOT BE COPIED, REPRODUCED OR CHANGED TO UNAUTHORIZED PERSONS WITHOUT THE EXPRESS WRITTEN CONSENT OF HDR POWER SYSTEMS.

AMETEK
HDR POWER SYSTEMS

SCHEMATIC
PF3, 30-1200A
OVER-CURRENT TRIP

DRAWN BY/DATE: JF 12/21/07
SCALE: NTS
CHECKED: GAS
CUSTOMER: APP'D BY GAS

DRAWING NO. S2710117
SHEET 1 OF 1
REVISION 1